

# QuietWalk Sound Test Summary

Test	Product	Test	Date	Lab	Report #	Test floor	Floor Covering	Result
Delta IIC	QuietWalk	EN ISO 140-8 (delta test)	12/2/2004	IFF	04/PC/PHY/3069	6" Concrete	Laminate - 8mm Steps Uniclic	$\Delta L_w = 20dB$
FIIC	QuietWalk	FIIC	8/26/2002	SSA Acoustics	Bellora Condos	7" Concrete (bare: no drop ceiling)	Floating Engineered Hardwood	60
FIIC	QuietWalk	FIIC	7/5/2001	Intertek	J20052639-003	8" Concrete (bare: no drop ceiling)	Armstrong Laminate	60
IIC	QuietWalk	IIC	8/21/2003	Intertek	3044125-001	6" Concrete with Intertek drop ceiling	3/8" Floating Engineered Wood	57
IIC	QuietWalk	IIC	8/21/2003	Intertek	3044125-001	6" Concrete with Intertek drop ceiling	1/2" Floating Engineered Wood	57
IIC	QuietWalk	IIC	9/16/2003	Intertek	3048291-001	6" Concrete with Intertek drop ceiling	Wilsonart Laminate	57
IIC	QuietWalk	IIC	7/26/2006	Intertek	3100878CRT-001a	6" Concrete with Intertek drop ceiling	Laminate - 8mm	60
IIC	QuietWalk	IIC	10/6/1999	Intertek	J99025595-001	Open Joist 2000 system. 16" deep, 24"oc, 5/8" plywood, 5 1/2" insulation resilient channels, 1 1/2" gypcrete	Formica laminate	53
IIC	QuietWalk	IIC	2/22/2005	NGC	NGC 7005008	6" Concrete with suspended gypsum ceiling with 3 1/2" insulation	8mm laminate	71
IIC	QuietWalk	IIC	7/16/2007	NGC	NGC 7007098	8" Concrete with suspended gypsum ceiling.	9/16" Engineered wood	68
STC	QuietWalk	STC	9/12/2000	Intertek	J2012659-003	Open Joist 2000 system. 16" deep, 24"oc, 5/8" plywood, 5 1/2" insulation resilient channels, 1 1/2" gypcrete	Formica laminate	52
STC	QuietWalk	STC	10/6/1999	Intertek	J99025595-002	Open Joist 2000 system. 16" deep, 24"oc, 5/8" plywood, 5 1/2" insulation resilient channels, 1 1/2" gypcrete	Formica laminate	52
STC	QuietWalk	STC	12/10/1999	Intertek	J99031102-002	Open Joist 2000 system. 16" deep, 24"oc, 5/8" plywood, 5 1/2" insulation resilient channels, 1 1/2" gypcrete	Pergo laminate	52
STC	QuietWalk	STC	12/10/1999	Intertek	J99031102-003	Open Joist 2000 system. 16" deep, 24"oc, 5/8" plywood, 5 1/2" insulation resilient channels, 1 1/2" gypcrete	Formica laminate	52
STC	QuietWalk	STC	9/9/2004	NGC	NGC 5004020	8" Concrete (bare: no drop ceiling)	8mm Laminate	54
STC	QuietWalk	STC	7/16/2007	NGC	NGC 5007047	8" Concrete with suspended gypsum ceiling.	9/16" Engineered wood	66